



**NOTES:**

1. CONCRETE SHALL BE 4000 PSI MIN. (CL 4000), 3-1/2" SLUMP (MAX.), MEDIUM BROOM FINISH PARALLEL TO DRIVEWAY CENTERLINE.
2. TO BE USED WHERE CURB AND SIDEWALK ARE SEPARATED BY A PLANTER STRIP.
3. COMMERCIAL DRIVEWAYS REQUIRE 8" CONCRETE WITH REINFORCING STEEL (6x6 - W2.9xW2.9 WWF, MIN.), 1 1/2" COVER FROM BOTTOM OF SLAB. RESIDENTIAL DRIVEWAYS REQUIRE 6" CONCRETE.
4. COMPACT SUBGRADE AND CRUSHED SURFACING TOP COURSE TO 95% OF MAXIMUM DRY DENSITY (3" MIN. DEPTH).
5. DRIVEWAYS EXCEEDING 15' IN TOTAL WIDTH SHALL HAVE ADDITIONAL LONGITUDINAL JOINTS AS DIRECTED. JOINT SPACING SHALL NOT EXCEED 15'. SEE **CONCRETE JOINTS DETAIL T05-02**.
6. EXISTING CURB SHALL BE REMOVED TO EXISTING JOINT OR SAWCUT SUCH THAT 3' MIN. OF NEW CURB IS CONSTRUCTED ADJACENT TO NEW DRIVEWAY.
7. SEE **PAVEMENT RESTORATION/WIDENING AT CURB DETAIL T05-01A** WHEN CUTTING EXISTING CURB.
8. ALL EXISTING EDGES SHALL BE SAWCUT.
9. STRUCTURAL SECTION OF DRIVEWAY TO BE EXTENDED THROUGH SIDEWALK AREA.
10. 3' WING MIN. FOR NON-ARTERIAL STREETS.
11. 45° ANGLE FOR WINGS ON ARTERIAL STREETS.
12. IF A FIRE HYDRANT OR WATER METER BOX IS SITE NEARBY, THERE SHALL BE A MIN. OF 5' BETWEEN THE EDGE OF CONCRETE (WING) AND THE FIRE HYDRANT ASSEMBLY OR METER BOX.
13. FOR RESIDENTIAL SUBDIVISIONS ONLY, THE CONTRACTOR MUST INSTALL ALL CURBS THROUGHOUT THE PROJECT AND DEFER THE CONSTRUCTION OF DRIVEWAY DROPS. DRIVEWAY DROPS WOULD THEN BE HORIZONTALLY SAWCUT INTO THE CURB FACE AT TIME OF HOUSE CONSTRUCTION.

I:\CITYPPS\AUTOCAD\STD\_DETAILS\DRAWING\_FILES\T01-04

REV NO.	DATE	BY	APPR	
1	1/15	RAW	MHA	
2	3/17	RAW	MHA	
3	4/18	RAW	MHA	
4	7/19	RAW	MHA	
5	2/21	OIS	MHA	
6	9/21	RAW	MHA	

**PUBLIC WORKS - STREETS AND TRANSPORTATION**

APPROVED BY: *M.H. Sedalla*  
ENGINEER MANAGER

APPROVED DATE: 9/1/2021



DRIVEWAY WITH DETACHED SIDEWALK	STANDARD PLAN NUMBER <b>T01-04</b>
------------------------------------	--