



**NOTES:**

1. CONCRETE SHALL BE 3000 PSI MIN. (CL 3000), 3 1/2" SLUMP (MAX.).
2. COMPACT SUBGRADE AND CRUSHED SURFACING TOP COURSE TO 95% OF MAXIMUM DRY DENSITY (3" MIN. DEPTH).
3. FINISH SHALL BE MEDIUM BROOM PERPENDICULAR TO PEDESTRIAN TRAFFIC UNLESS OTHERWISE DIRECTED.
4. 2" SMOOTH FINISH BORDER AROUND EACH SIDEWALK PANEL OR MATCH EXISTING BORDER.
5. SEE **CONCRETE JOINTS DETAIL T05-02** FOR SURFACE, CONTRACTION, AND EXPANSION JOINTS.
6. ALL EXISTING EDGES SHALL BE SAWCUT.
7. CROSS SLOPE OF PLANTER STRIP SHALL BE 2% (TYP.) AND 4:1 (MAX.).
8. ALL SIDEWALK REMOVAL AND REPLACEMENT SHALL BE JOINT TO JOINT.
9. SIDEWALK REPLACEMENT AREAS SHALL BE ROCKED LEVEL AND COMPACTED UNTIL CONCRETE IS PLACED.
10. FIRE HYDRANT OR WATER METER BOX SHALL NOT BE WITHIN THE SIDEWALK.

I:\CITYPPS\AUTOCAD\STD\_DETAILS\DRAWING\_FILES\T02-01A

REV. NO.	DATE	BY	APPR	DESCRIPTION
1	7/14	RAW	MHA	
2	1/15	RAW	MHA	
3	3/17	RAW	MHA	
4	4/18	RAW	MHA	
5	2/21	OIS	MHA	
6	9/21	RAW	MHA	

PUBLIC WORKS - STREETS AND TRANSPORTATION

APPROVED BY: *M.H. Pedraza*  
ENGINEER MANAGER

APPROVED DATE: 9/1/2021



SIDEWALK DETAIL	STANDARD PLAN NUMBER T02-01A
-----------------	---------------------------------