



NOTES:

1. CONTRACTOR RESPONSIBLE FOR LOCATING DRAIN VALVE AT LOWEST POINT OF MAINLINE TO ENSURE POSITIVE DRAINAGE.
2. ALLOW FOR 1" CLEARANCE FROM HOLE IN BOX TO TOP OF PIPE.

I:\CITYAPPS\AUTOCAD\STD_DETAILS\DRAWING_FILES\T03-11

REV NO.	DATE	BY	APPR	
1	2/07	RAW	MHA	
2	8/08	RAW	MHA	
3	7/14	RAW	MHA	
4	9/21	RAW	MHA	

PUBLIC WORKS – STREETS AND TRANSPORTATION

APPROVED BY: *M.H. Pedulla*
ENGINEER MANAGER

APPROVED DATE: 9/1/2021



MANUAL DRAIN VALVE	STANDARD PLAN NUMBER T03-11
--------------------	--------------------------------