



NOTES:

1. WRAP ALL THREADED FITTINGS WITH TEFLON TAPE.
2. MINIMUM SWING JOINT SIZE SHALL BE HEAD BOTH INLET SIZE.
3. WHEN SPRAY HEADS ARE RUNNING ALONG SIDEWALK OR CURBS, HEADS SHOULD BE 3" AWAY AND PIPES 6" OR MORE AWAY.

I:\CITYPPS\AUTOCAD\STD_DETAILS\DRAWING_FILES\T03-15

REV. NO.	DATE	BY	APPR
1	2/07	RAW	MHA
2	8/08	RAW	MHA
3	7/14	RAW	MHA
4	9/21	RAW	MHA

PUBLIC WORKS – STREETS AND TRANSPORTATION

APPROVED BY: *M.H. Pedulla*
ENGINEER MANAGER

APPROVED DATE: 9/1/2021



POP-UP SPRAY HEAD	STANDARD PLAN NUMBER T03-15
-------------------	--------------------------------