



**NOTES:**

1. CONCRETE CURBS SHALL BE 3000 PSI MIN. (CL 3000), 3-1/2" SLUMP (MAX.), DRIVEWAY OPENINGS SHALL BE 4000 PSI MIN. (CL 4000).
2. CURBS ADJACENT TO PAVEMENT OR SIDEWALK SHALL HAVE EXPANSION AND/OR CONSTRUCTION JOINTS TOMATCH EXISTING PATTERNS. 3/8" EXPANSION JOINTS SHALL BE PLACED ON BOTH SIDES OF CATCH BASINS, ALL CHANGES IN DIRECTION, AND AS DIRECTED BY THE INSPECTOR. CONTRACTION JOINTS TO BE PLACED AT 15' MAXIMUM SPACING.
3. COMPACT SUBGRADE AND CRUSHED SURFACING TOP COURSE TO 95% MAXIMUM DRY DENSITY (6" MIN. DEPTH).
4. CURB TO BE MEDIUM BROOM FINISHED, PARALLEL TO GUTTER LINE.

I:\CITYPPS\AUTOCAD\STD\_DETAILS\DRAWING\_FILES\T08-30

REV NO.	DATE	BY	APPR
1	9/21	RAW	MHA

**PUBLIC WORKS – STREETS AND TRANSPORTATION**

APPROVED BY: *MHA*  
ENGINEER MANAGER

APPROVED DATE: 9/1/2021



HEIGHTS DISTRICT  
REDEVELOPMENT  
CONCRETE VALLEY GUTTER

STANDARD PLAN NUMBER  
T08-30