


NOTES:
APPROVED MATERIALS LIST:
 SEE CITY OF VANCOUVER'S WEB SITE;
<http://www.cityofvancouver.us/publicworks/page/transportation-development-review-information>



**ALL SPLICES SHALL BE COMPRESSION
 DO NOT USE WIRE NUTS**

SPLICE NO. 8/2 AND NO. 12 CONDUCTORS
 HERE WITH 10A FUSE VIA HANDHOLE 3"x5"
 OPENING WITH COVER AND TAMPER PROOF
 STAINLESS STEEL SCREWS.

2' MIN. TO FACE OF CURB
 SEE T21-16 LIGHTING
 STANDARD POSITION OPTIONS

20'-0"

SEE SPECIFICATIONS
 FOR FOUNDATION
 DEPTH AND SIZE

1'-6"

DIRECT BURIAL, SEE DETAIL
 T21-10

NOTE:
 LIGHTING STANDARD TYPE N CAN BE
 USED ALONG RESIDENTIAL OR LOCAL
 ACCESS STREET ONLY OR MATCHING THE
 SURROUNDING NEIGHBORHOOD.

I:\CITYAPPS\AUTOCAD\STD_DETAILS\DRAWING_FILES\T21-08

REV NO.	DATE	BY	APPR	AGE
1	3/06	RAW		AGE
2	4/06	RAW		AGE
3	2/07	RAW		AGE
4	8/08	RAW		AGE
5	1/15	RAW	CJC	
6	9/21	RAW	CJC	

PUBLIC WORKS - STREETS
 AND TRANSPORTATION

APPROVED BY: *[Signature]*
 TRAFFIC ENGINEER MANAGER

APPROVED DATE: 9/1/2021



TYPE N LIGHTING STANDARDS	STANDARD PLAN NUMBER T21-08
------------------------------	-----------------------------------