


NOTES:

1. CONTRACTOR MUST BE UL APPROVED AND UL 508 CERTIFIED TO BUILD AND INSTALL.
2. SAFETY SWITCH BOX SHALL BE SCHNEIDER ELECTRIC PART #DU222RB OR APPROVED EQUAL.

I:\CITYAPPS\AUTOCAD\STD_DETAILS\DRAWING_FILES\T21-18B

| REV NO. | DATE | BY | APPR |
|---------|------|-----|------|
| 1 | 2/21 | RAW | CJC |
| 2 | 9/21 | RAW | CJC |
| | | | |
| | | | |

PUBLIC WORKS – STREETS AND TRANSPORTATION

APPROVED BY: 
 TRAFFIC ENGINEER MANAGER
 APPROVED DATE: 9/1/2021



STREET LIGHT DISCONNECT DETAIL

STANDARD PLAN NUMBER
T21-18B