



(MODIFIED R7-107)

NOTES:

1. **"NO PARKING FIRE LANE"** SHALL BE POSTED WHEREVER PARKING COULD OBSTRUCT THE REQUIRED 20' FIRE APPARATUS ACCESS LANE. "NO PARKING FIRE LANE" SHALL BE POSTED TO THE FOLLOWING STANDARDS:
 - ACCESS ROADS LESS THAN 28' NO PARKING ALLOWED ON STREET;
 - ACCESS ROADS 28' TO 36' PARKING ONLY ON ONE (1) SIDE;
 - ACCESS ROADS 36' AND GREATER PARKING ON BOTH SIDES.
 - CUL-DE-SACS THAT ARE SPECIFICALLY REQUIRED BY THE FIRE DEPARTMENT FOR TURN-AROUND WITH A RADIUS OF LESS THAN 43' NO PARKING IN RADIUS OF CUL-DE-SAC.
2. PARKING RESTRICTION SIGNS SHALL BE INSTALLED AT 45° TO ROADWAY.
3. FOR ADDITIONAL INFORMATION, SEE COV VANCOUVER FIRE MARSHAL'S OFFICE STD. PLAN F-503.3.

I:\CITYPPS\AUTOCAD\STD_DETAILS\DRAWING_FILES\T29-09

REV NO.	DATE	BY	APPR	AGE
1	1/05	RAW	AGE	
2	3/06	RAW	AGE	
3	2/07	RAW	AGE	
4	8/08	RAW	AGE	
5	1/15	RAW	CJC	
6	9/21	RAW	CJC	

PUBLIC WORKS - STREETS AND TRANSPORTATION

APPROVED BY: *[Signature]*
TRAFFIC ENGINEER MANAGER

APPROVED DATE: 9/1/2021



NO PARKING FIRE LANE SIGN DETAIL	STANDARD PLAN NUMBER T29-09
--	-----------------------------------