



NOTE:

1. WHEN CURB DRAINS ARE USED, DRAINAGE FACILITIES MUST BE SIZED FOR BOTH QUANTITY AND QUALITY STORM WATER TREATMENT.
2. DETACHED SIDEWALK SHOWN. ATTACHED SIDEWALK AND CITY CENTER SIDEWALK SIMILAR.
3. FINISH PIPE END FLUSH WITH FACE OF CURB.
4. GROUT ANY VOIDS IN CONCRETE SURROUNDING PIPE.
5. SHOW LOCATION ON PLAN TO AVOID CONFLICT'S WITH STREET LIGHTS, FUTURE DRIVEWAY DROPS, WATER METERS AND OTHER UTILITIES.
6. CURB DRAINS NOT ALLOWED IN ROLLED CURBS.
7. CONNECT SLEEVE AND CURB DRAIN SO THAT THE CONNECTION IS WATERTIGHT.



CURB DRAIN				STD. PLAN NO. T01-03
CITY OF VANCOUVER DEPARTMENT OF PUBLIC WORKS TRANSPORTATION DIVISION		DRAWN BY CDC	APPROVED BY <i>MATE</i>	
		REVISION 7	APPROVED BY <i>MATE</i>	APPROVAL DATE 3/24

I:\CITYAPPS\AUTOCAD\STD_DETAILS\DRAWING_FILES\T01-03.DWG