

NOTES:

_FILES\T02-09A

- 1. AN UNOBSTRUCTED PATH OF TRAVEL WITH A MINIMUM WIDTH OF 4' SHALL BE MAINTAINED.
- COMPACT SUBGRADE AND CRUSHED SURFACING TOP COURSE TO 95% OF MAXIMUM DRY DENSITY (3" MIN. DEPTH).
- 3. IF THE AREA BEHIND THE SIDEWALK IS VEGETATED THE BACK CURB MAY BE REPLACED WITH A SLOPE NO STEEPER THAN 4:1.
- 4. IF THE MAXIMUM SLOPE OF 8.3%** CANNOT BE ACHIEVED DUE TO THE SLOPE OF THE EXISTING SIDEWALK, THE LENGTH OF THE CURB RAMP SHALL NOT BE REQUIRED TO BE LONGER THAN 15 FEET REGARDLESS OF THE RESULTING RAMP SLOPE.
- 6. AT THE TOP OF EACH RAMP A 5'X5' LANDING AREA SHALL BE CONSTRUCTED AND THE LONGITUDINAL CROSS SLOPE SHALL NOT EXCEED 2%* EACH DIRECTION.
- 7. SEE PAVEMENT RESTORATION/WIDENING AT CURB DETAIL TO5-01A WHEN CUTTING EXISTING CURB.
- 8. RAMP CROSS SLOPE SHALL BE 27 MAXIMUM.
- 9. TYPE A-1 AND E-1 CURB (SEE CONCRETE CURB DETAIL TO1-01A) POURED SEPARATELY FROM RAMPS.
- 10. ADA RAMP AND GRADE CORRECTION CURBS POURED MONOLITHICALLY.



SINGLE DIRECTIONAL CURB RAMP ATTACHED SIDEWALK

CITY OF VANCOUVER
DEPARTMENT OF PUBLIC WORKS
TRANSPORTATION DIVISION

	4	MH)	3/24
1	REVISION	APPROVED BY	APPROVAL DATE
1	CDC	MHH):	3/17
	DRAWN BY	APPROVED BY	APPROVAL DATE

T02-09A