## NOTES:

- CONTRACTOR RESPONSIBLE FOR LOCATING DRAIN VALVE AT LOWEST POINT OF MAINLINE TO ENSURE POSITIVE DRAINAGE.
- 2. ALLOW FOR 1" CLEARANCE FROM HOLE IN BOX TO TOP OF PIPE.



## **MANUAL DRAIN VALVE**

	5	MHI	3/24
1	REVISION	APPROVED BY	APPROVAL DATE
	CDC	MHH	2/07
	DRAWN BY	APPROVED BY	APPROVAL DATE