



NOTES:

- ① WEATHERPROOF, WATER TIGHT J-BOX WITH WATER TIGHT CONNECTIONS TO CONDUIT AND RECEPTACLE CORD BOX TO BE LOCATED 4"–8" BELOW GRATE ACCESS BOX TO (AND?) ANCHORED TO BOX.
- ② CIRCUITING CONTINUED IN CONDUIT. MINIMUM 18" DEPTH. MINIMUM 4' OF GALVANIZED RIGID CONDUIT FROM TERMINATION TO WEATHER PROOF BOX. 3 PIECE COUPLINGS AT THE BOX ARE ACCEPTABLE WHEN THREADS ARE TREATED WITH NEVER SIEZE.
- ③ 4' (3) CONDUCTOR OUTDOOR RATED FLEXIBLE CABLE. RATED FOR OUTDOOR WET LOCATION USE. SOUTH WIRE 'SJEOW' OR APPROVED EQUAL.
- ④ WATERTIGHT TWIST-LOCK RECEPTACLE WITH SAFETY SHROUD. HUBELL HBL 15W47. NEMA 5-15R OR APPROVED EQUAL.



ELECTRICAL OUTLET DETAIL FOR TREE WELL

CITY OF VANCOUVER
DEPARTMENT OF PUBLIC WORKS
TRANSPORTATION DIVISION

DRAWN BY	APPROVED BY	APPROVAL DATE
CDC	<i>MAHE</i>	2/21
REVISION	APPROVED BY	APPROVAL DATE
3	<i>MAHE</i>	3/24

STD. PLAN NO.

T03-25