



NOTES:

1. CONCRETE CURBS SHALL BE 3000 PSI MIN. (CL 3000), 3-1/2" SLUMP (MAX.), DRIVEWAY OPENINGS SHALL BE 4000 PSI MIN. (CL 4000).
2. CURBS ADJACENT TO PAVEMENT OR SIDEWALK SHALL HAVE EXPANSION AND/OR CONSTRUCTION JOINTS TO MATCH EXISTING PATTERNS. 3/8" EXPANSION JOINTS SHALL BE PLACED ON BOTH SIDES OF CATCH BASINS, ALL CHANGES IN DIRECTION, AND AS DIRECTED BY THE INSPECTOR. CONTRACTION JOINTS TO BE PLACED AT 15' MAXIMUM SPACING.
3. COMPACT SUBGRADE AND CRUSHED SURFACING TOP COURSE TO 95% MAXIMUM DRY DENSITY (6" MIN. DEPTH).
4. CURB TO BE MEDIUM BROOM FINISHED, PARALLEL TO GUTTER LINE.

I:\CITYAPPS\AUTOCAD\STD_DETAILS\DRAWING_FILES\T08-30.DWG



**HEIGHTS DISTRICT REDEVELOPMENT
CONCRETE VALLEY GUTTER**

CITY OF VANCOUVER
DEPARTMENT OF PUBLIC WORKS
TRANSPORTATION DIVISION

DRAWN BY	APPROVED BY	APPROVAL DATE
CDC	<i>M.H.H.</i>	9/21
REVISION	APPROVED BY	APPROVAL DATE
2	<i>M.H.H.</i>	3/24

STD. PLAN NO.
T08-30