



- NOTES:**
1. 2" MINIMUM OF CONCRETE COVER ON ALL STRUCTURAL SUPPORT BARS.
 2. CONDUITS SHALL EXTEND 2" MIN. AND 3" MAX. ABOVE CONCRETE MEASURED TO END OF BELL OR GROUND BUSHING.
 3. ENSURE ALL DOORS CAN SWING OPEN 180 DEGREES.
 4. SEE WSDOT STD. PLAN J-10.10 FOR SPECIFICATIONS.

I:\CITYAPPS\AUTOCAD\STD_DETAILS\DRAWING_FILES\T20-38EA.DWG



TYPE "P" CABINET AND SERVICE COMBINATION FOUNDATION

CITY OF VANCOUVER
DEPARTMENT OF PUBLIC WORKS
TRANSPORTATION DIVISION

DRAWN BY	APPROVED BY	APPROVAL DATE
CDC		3/17
REVISION	APPROVED BY	APPROVAL DATE
3		3/24

STD. PLAN NO.
T20-38EA