



**NOTES:**

1. SEE SERVICE ENCLOSURE REQUIREMENTS ON STD. PLAN T20-41.
2. SEE WIRING DIAGRAM ON STD. PLAN T20-39B.
3. IF SERVICE CABINET IS INSTALLED ADJACENT TO CONTROLLER CABINET, SEE STD. PLAN T20-38EA OR T20-38EB FOR PLACEMENT.
4. PLACE A SILICONE SEAL BETWEEN THE FOUNDATION AND THE CABINET.
5. ENCLOSURE SHALL BE TESCO CLASS 27-000M.
6. ALUMINUM CONDUCTORS NOT ALLOWED.
7. FOLLOW WSDOT STANDARD PLANS FOR ADDITIONAL GROUND ROD INSTALLATION.
8. SEE FOUNDATION PLAN ON STD. PLAN T20-39C.

I:\CITYAPPS\AUTOCAD\STD\_DETAILS\DRAWING\_FILES\T20-39A.DWG



**TRAFFIC SIGNAL SERVICE CABINET**

CITY OF VANCOUVER  
DEPARTMENT OF PUBLIC WORKS  
TRANSPORTATION DIVISION

DRAWN BY	APPROVED BY	APPROVAL DATE
CDC		8/04
REVISION	APPROVED BY	APPROVAL DATE
7		3/24

STD. PLAN NO.  
**T20-39A**