



NOTES:

1. SEE SERVICE ENCLOSURE REQUIREMENTS ON STD. PLAN **T20-41**.
2. SEE WIRING DIAGRAM ON STD. PLAN **T21-15B**.
3. PLACE A SILICONE SEAL BETWEEN THE FOUNDATION AND THE CABINET.
4. ENCLOSURE SHALL BE TESCO CLASS 27-000M.
5. ALUMINUM CONDUCTORS NOT ALLOWED.
6. FOLLOW WSDOT STANDARD PLANS FOR ADDITIONAL GROUND ROD INSTALLATION.
7. SEE FOUNDATION PLAN ON STD. PLAN **T21-15C**.

I:\CITYAPPS\AUTOCAD\STD_DETAILS\DRAWING_FILES\T21-15A.DWG



STREET LIGHT CONTACTOR CABINET

CITY OF VANCOUVER
DEPARTMENT OF PUBLIC WORKS
TRANSPORTATION DIVISION

DRAWN BY	APPROVED BY	APPROVAL DATE
CDC		8/04
REVISION	APPROVED BY	APPROVAL DATE
7		3/24

STD. PLAN NO.
T21-15A