



(MODIFIED R7-107)

**NOTES:**

1. **"NO PARKING FIRE LANE"** COULD BE POSTED WHEREVER PARKING COULD OBSTRUCT THE REQUIRED 20' FIRE APPARATUS ACCESS LANE. "NO PARKING FIRE LANE" SHALL BE POSTED TO THE FOLLOWING STANDARDS:
  - ACCESS ROADS LESS THAN 28' NO PARKING ALLOWED ON STREET;
  - ACCESS ROADS 28' TO 36' PARKING ONLY ON ONE (1) SIDE;
  - ACCESS ROADS 36' AND GREATER PARKING ON BOTH SIDES.
  - CUL-DE-SACS THAT ARE SPECIFICALLY REQUIRED BY THE FIRE DEPARTMENT FOR TURN-AROUND WITH A RADIUS OF LESS THAN 43' NO PARKING IN RADIUS OF CUL-DE-SAC.
2. PARKING RESTRICTION SIGNS SHALL BE INSTALLED AT 45° TO ROADWAY.
3. FOR ADDITIONAL INFORMATION, SEE COV VANCOUVER FIRE MARSHAL'S OFFICE STD. PLAN F-503.3.

I:\CITYAPPS\AUTOCAD\STD\_DETAILS\DRAWING\_FILES\T29-09.DWG



**NO PARKING FIRE LANE SIGN DETAIL**

CITY OF VANCOUVER  
DEPARTMENT OF PUBLIC WORKS  
TRANSPORTATION DIVISION

DRAWN BY	APPROVED BY	APPROVAL DATE
CDC		1/05
REVISION	APPROVED BY	APPROVAL DATE
7		3/24

STD. PLAN NO.  
**T29-09**